# **Supplier Declaration of Conformity (SDOC)**

(in accordance with ISO/IEC 17050-1:2004)



<b>SDoC Identification Number:</b>	NHPMOD6.004

### NHP Electrical Engineering Products (N.Z.) Ltd

118a Carbine Road Mt Wellington Auckland 1060 New Zealand NZ Company No: 931377

NZ Company No: 931377 Telephone +64 9 276 1967 Fax +64 800 329 647 www.nhp-nz.com

# NHP Electrical Engineering Products Pty Ltd

43-67 River Street Richmond Victoria 3121 Australia A.B.N. 84 004 304 812 Telephone +61 3429 2999 Fax +61 3429 1075 www.nhp.com.au

-				
Pro	duct	1	Δtai	C.
110	uuc	ιu	ctai	12.

#### Product model:

NHP MOD6 RCBO's - Catalogue No M6RCBDxxxxx

# Description/Ratings:

Breaking capacity: 6kA Rated Residual Current: 30mA

RCD Type: A & AC

Number of poles: 1P+N (Width: 18mm) Current Rating: 6A, 10A, 16A, 20A, 25A & 32A

Curve Type: C Voltage: 230VAC

# The products listed above is in conformity with the following Standard(s)/Normative Documents:

# Standard/Document:

AS/NZS-61009-1

#### **Test reports/Certificates:**

NSW24576- Certificate of Approval from NSW Department of Fair Trading

# **Product Markings:**

Approval No: NSW24576 or RCM mark				
Name:	Justin Charlot			
Product Manager MCB, RCDs and Isolators				

Date:	26/06/2013	Signature of Authorised Person:	Swelliam
-------	------------	---------------------------------	----------