

Supplier Declaration of Conformity (SDOC)

(in accordance with ISO/IEC 17050-1:2004)



SDoC Identification Number: NHPMOD6.006

NHP Electrical Engineering Products (N.Z.) Ltd
118a Carbine Road
Mt Wellington
Auckland 1060
New Zealand
NZ Company No: 931377
Telephone +64 9 276 1967
Fax +64 800 329 647
www.nhp-nz.com

NHP Electrical Engineering Products Pty Ltd
43-67 River Street
Richmond
Victoria 3121
Australia
A.B.N. 84 004 304 812
Telephone +61 3429 2999
Fax +61 3429 1075
www.nhp.com.au

Product details:

Product model:

NHP MOD6 RCCB's – Catalogue No MOD6RCCBxxxxx

Description/Ratings:

Rated Residual Current: 30mA
Number of poles: 2 & 4 pole
RCD Type: A & AC
Current Rating: 40 & 63 A
Voltage: 230/400VAC

The products listed above is in conformity with the following Standard(s)/Normative Documents:

Standard/Document:

AS/NZS-61008-1

Test reports/Certificates:

N17482– Certificate of Approval from NSW Department of Fair Trading

Product Markings:

Approval No: N17482 or RCM mark



Name:

Justin Charlot

Position:

Product Manager MCB, RCDs and Isolators

Date:

25/06/2013

Signature of Authorised Person: