

# Supplier Declaration of Conformity (SDOC)



(in accordance with ISO/IEC 17050-1:2004)

## SDoC Identification Number: NHPCPL.001

NHP Electrical Engineering Products (N.Z.) Ltd  
118a Carbine Road, Mt Wellington  
Auckland 1060  
New Zealand  
NZ Company No: 931377  
Telephone +64 9 276 1967  
www.nhp-nz.com

NHP Electrical Engineering Products Pty Ltd  
43-67 River Street, Richmond  
Victoria 3121  
Australia  
A.B.N. 84 004 304 812  
Telephone +61 3429 2999  
www.nhp.com.au

### Product details:

#### Product model:

CPL24G, CPL240  
CPL36G, CPL360  
CPL48G, CPL480  
CPL60G, CPL600  
CPL72G, CPL720  
CPL84G, CPL840  
CPL96G, CPL960

#### Description/Ratings:

Pole Capacity: 24, 36, 48, 60, 72, 84, 96  
Current Rating  $I_{nA}$ : 250A  
Main Switch: N/A  
Busbar Rating: 250A  
IP Rating: 42 (52 with kit)  
Short circuit rating  $I_{cw}$ : 25kA 0.1s (10kA 1.0s)  
Rated Diversity Factor RDF: 0.6 (63A)  
Rated Operational Voltage  $U_e$ : 230/400 – 240/415V 50 Hz  
Form of Separation: 2b (When fitted CEL3xxx main switch)  
Impact Rating: IK 10

### The products listed above is in conformity with the following Standard(s)/Normative Documents:

#### Standard/Document:

- AS/NZS: 61439.1:2016, Annex D Table D.1 List of design verification to be performed
- AS/NZS: 61439.2:2016, CL10 Design verification
- AS/NZS: 61439.3:2016, CL10 Design verification (Product is marked AS/NZS 61439.3)

#### Test reports/Certificates:

No.	Characteristic to be verified	Clause or Subclause	Tested	Comparison with a reference design	Assessment	Test Report (s) / Comments
	Strength of Material and parts	10.2				
	Resistance to corrosion	10.2.2	✓			CE TR2945A-R1
	Properties of insulating materials	10.2.3				
	Thermal stability	10.2.3.1				Assessed and deemed not required as enclosure is metallic
1	Resistance to abnormal heat and fire due to internal electric effects	10.2.3.2	✓			TUV50203205001 & TUV50227631001
	Resistance to UV radiation	10.2.4				Assessed and deemed not required as is for indoor applications
	Lifting	10.2.5				Assessed and deemed not required as there are no specific lifting points
	Mechanical impact	10.2.6	✓			TUV AU21W2IS001
	Marking	10.2.7	✓			NHP202104-01

☐ = Not allowed

# Supplier Declaration of Conformity (SDOC)



(in accordance with ISO/IEC 17050-1:2004)

**SDoC Identification Number: NHPCPL.001**

No.	Characteristic to be verified	Clause or Subclause	Tested	Comparison with a reference design	Assessment	Test Report (s) / Comments
2	Degree of protection of enclosures	10.3	✓			TUV50094013001 (IP42) TUV50153985001 (IP52)
3	Clearance	10.4	✓			NHP202105-08
4	Creepage Distances	10.4	✓			NHP202105-07
	Protection against electric shock and integrity of protective circuits	10.5				
5	Effective continuity between the exposed conductive part of the assemble and the protective circuit	10.5.2	✓			Tested and passed by TÜV Rheinland Australia, awaiting final test report No.
	Short circuit withstand strength of the protective circuit	10.5.3	✓	✓		TUV 50074477001 & TUV AU21SXHF001
6	Incorporating of switching devices and components	10.6			✓	NHP202103-07
7	Internal electrical circuits and connections	10.7			✓	NHP202103-08
8	Terminals for external conductors	10.8			✓	NHP202103-09
	Dielectric Properties	10.9				
9	Power-frequency withstand voltage	10.9.2	✓			NHP202103-03
	Impulse withstand voltage	10.9.3	✓			NHP202103-06
10	Temperature-rise limits	10.10	✓	✓		NHP202105-03 & NHP201908-01
11	Short-circuit withstand strength	10.11	✓	✓		TUV AU21S3J8 001 & TUV AU210NHE001 & TUV AU21ORIA001 & TUV AU21CWIR001 & TUV AU211OT0001 & TUV AU21DMNT001 & TUV AU21RI56001 & TUV AU21YGYD00 & TUV AU21ZK4Q001
12	Electro magnetic compatibility (EMC)	10.12				Not required, incorporated devices comply and installed to EMC requirements
13	Mechanical operation	10.13	✓			NHP202105-06
	Mechanical strength or fastening mean of enclosures	10.101	✓			NHP202104-02
	Fixing in position of pole fillers to comply IP2XC of 8.2.2	10.102	✓			NHP202104-03

■ = Not allowed

**Name:** Jamie Goddard  
**Position:** Product Manager—Distribution systems and Protection  
**Date:** 24/05/2021



**Signature of Authorised Person**