

Supplier Declaration of Conformity (SDOC)

(in accordance with ISO/IEC 17050-1:2004)



SDoC Identification Number: NHPNLINE.007

NHP Electrical Engineering Products (N.Z.) Ltd

118a Carbine Road
Mt Wellington
Auckland 1060
New Zealand
NZ Company No: 931377
Telephone +64 9 276 1967
Fax +64 800 329 647
www.nhp-nz.com

NHP Electrical Engineering Products Pty Ltd

43-67 River Street
Richmond
Victoria 3121
Australia
A.B.N. 84 004 304 812
Telephone +61 3429 2999
Fax +61 3429 1075
www.nhp.com.au

Product details:

Product model:

NHP NLINE - Catalogue No. NL432PV

Description/Ratings:

Assembly of switch and dedicated individual enclosure— catalogue number	NL432PV
<i>I_{the}</i> rated thermal current, indoor, at 40°C shade ambient air temperature, in a specific dedicated enclosure	32 A
<i>I_{the}</i> rated thermal current outdoors at 40°C shade ambient air temperature without solar effects in a specific dedicated enclosure IP 66NW	32 A
<i>I_{the}</i> solar current value, outdoors at 60°C shade ambient air temperature, with solar effects in a specific dedicated enclosure rated IP 66NW	29 A
Method of operation	Independent manual operation (rotary)
Utilisation category	DC-PV2 / DC-21B
Number of poles	4
Polarity	No polarity
Suitable for isolation	Yes
<i>I_{the}</i> rated thermal current outdoors at 40°C shade ambient air temperature without solar effects in a specific dedicated enclosure IP 66NW (A)	32
Rated insulation voltage U_i (V)	1500
Rated impulse withstand voltage U_{imp} (kV)	8
Rated short-time withstand current I_{cw} (kA)	A2, A4: 1kA, 1s
	A2+2, A4B, A4O, A4U: 1.7kA, 1s
Cu cable cross section (mm ²)	Rigid solid/stranded: 4 – 16
	Flexible: 4 – 10
Cable Striping Length (mm)	12
IP rating (with / without pressure compensation device)	IP66NW
Pollution degree	3
Operating temperature (°C)	-40 to +85, suitable for indoor or outdoor use
Maximum ambient temperature (°C)	+70 (without derating)

Supplier Declaration of Conformity (SDOC)

(in accordance with ISO/IEC 17050-1:2004)



SDoC Identification Number: NHPNLINE.007

Connection Code*	U_o Rated Operational Voltage (V D.C.)	I_o ; DC-PV2 Rated Operational current (A)	$I_{(make)}$ and $I_{c(break)}$ DC-PV2 $4 \times I_e$ (A)
A2 (2 poles in series)	≤ 500	32	128
	600	32	128
	800	32	128
	1000	13	52
	1200	13	52
	1500	5	20
A2 + 2 (2 parallel poles in series)	≤ 500	55	220
	600	55	220
	800	55	220
	1000	13	52
	1200	13	52
	1500	6	24
A4 (2 poles in series)	≤ 500	32	128
	600	32	128
	800	32	128
	1000	13	52
	1200	13	52
	1500	5	20
A4B / A4O / A4U (4 poles in series)	≤ 500	32	128
	600	32	128
	800	32	128
	1000	32	128
	1200	32	128
	1500	23	92

The products listed above is in conformity with the following Standard(s)/Normative Documents:

Standard/Document:

AS 60947.3:2018
AS/NZS IEC 60947.1:2015

Test reports/Certificates:

Certificate of Approval no.: AZ69024730
Test report No.: 60427305 001 and 1W180103-B1

Product Markings:

RCM mark and TUV authorised marking:



TUV024730EA

Name: Christian James

Position: Product Development Manager

Date: 29/03/2021

Signature of Authorised Person: